



THE MANUFACTURE RESERVES THE RIGHT TO SUBSTITUTE/CHANGE COMPOMPONENTS OF THE SYSTEM AS DEEMED NECESSARY WITHOUT PRIOR NOTICE TO THE CUSTOMER, THESE COMPONENTS WILL BE COVERED BY THE MANUFACTURER'S WARRANTY.

BILL OF MATERIAL VersaChlor III(A)

ITEM	QUAN.	DESCRIPTION
1	1	CYLINDRICAL TANK WITH LID, 30 GALLON
2A	1	MILLER PLASTICS FLOAT VALVE, 3/4-0.590-3/4
2B	1	6" 316 SS ROD
2C	1	4" x 5" LG. FLOAT BALL
3	1	3/4" STREET ELL, MPT X SOC, SCH. 40 PVC
4	1	3/4" X 3/4" X 1" SOC TEE, SCH. 40 PVC
5	A.R.	3/4" SCH. 40 PVC PIPE
6	1	3/4" SCH. 40 PVC MALE ADAPTOR
7	1	3/4" PVC BULKHEAD FITTING
8	1	3/4" SCH. 40 PVC PLUG
9	1	1/2" SCH. 40 PVC PLUG
10	1	1" SOC X 3/4" FPT ADAPTOR, SCH. 40 PVC
11	2	3/4" 90° ELL, FPT X FPT, SCH. 40 PVC
12	1	FLOWMETER, BLUE & WHITE F-44750L-12 (1-10 GPM)
13	1	3/4" MALE ADAPTOR, SCH. 40 PVC
14	1	1" SOC X 3/4" MPT ADAPTOR, SCH. 40 PVC
15	A.R.	1" SCH. 40 PVC PIPE
16	1	1" RUSCO STRAINER
17	1	1" BULKHEAD FITTING, T X T
18	1	1" STREET ELL, MPT X SOC, SCH. 40 PVC
19	1	1" CLOSE THD. PVC NIPPLE
20	1	1" PVC GATE VALVE, FPT
21	1	1" MALE ADAPTOR, SCH. 40 PVC
22	1	3/8" PVC SIEVE PLATE-(1) 7" HOLE
23	1	SIEVE PLATE DISTRIBUTOR-6" DIWV CAP.
24	1	3/8" PVC SIEVE BASKET-(33) 3/8" HOLES W/ 7 7/8" x 20" PVC-SLEEVE (2) - 1/2" HOLES
25	1	SIEVE PLATE SUPPORT LEGS, (4) 1 1/2" SCH. 40 PVC PIPES X 17 7/8" LONG
26	1	1" SCH. 40 PVC PIPE X 2 1/2" LONG FOR SPARGER WITH (8) 3/8" HOLES, 1/2" FROM END
27	1	FABRICATED PVC CAP FOR SPARGER TUBE
SYSTEM OPTIONS		
29	4	WEDGE FEET
30	1	1 1/2" RUSCO 100 MESH INLET FILTER
31	1	2" RUSCO 100 MESH INLET FILTER
32	1	WEBTROL PUMP, 0.75 HP
33	1	1" PRE-WIRED SOLENOID VALVE (CABLE/PLUG)



SYSTEM PLAN



SYSTEM ELEVATION

TITLE: AXIALL VERSACHLOR III(A) CHLORINATOR WITH EQUIPMENT LIST & TABS	
 WTP	DRAWN: RMH DATE: 25 MAY 2017
	SCALE: 1/4" = 1'
	DWG: VERSACHLOR III(A)
	REV: 0